

FIRE SAFETY CERTIFICATE

No. MBMC / FIRE / 830 / 2024 - 25

DATE: 22/07/2024

Certified that **RAHUL INTERNATIONAL SCHOOL** at Sr. No 266 (67)/ 7, 268 (53)/ 1, 269 (54)/ 2 Village Navghar, Mira Road East, Dist - Thane 401107 comprised of ground floor and G + 08 (upper floors) is owned/ occupied by Rahul International School complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 22/ 07/ 2024 (date of inspection) in the presence of **Mr. Yigal S. Banker Principal Rahul International School** at Sr. No 266 (67)/ 7, 268 (53)/ 1, 269 (54)/ 2 Village Navghar, Mira Road East, Dist - Thane 401107 and that the building / premises is fit for occupancy up to classes XII (X/ XII) With effect from 22/ 07/ 2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

A) Fire Wet Riser Cum Down Come System Each Staircase

- Landing Valve provide on each floor,
- Hose Box with Hose,
- Branch pipe each floor & Ground level for Stand Post,
- Fire Stand Post - 05 nos.
- Hose drum with hose reel on each floor,
- Booster Pump - 01 no.
- Main control panel for above pump - 01 set
- Fire Brigade inlet at Ground level

B) Fire Extinguisher ABC Type (4 Kgs.) - 18 nos.Issued on Date. 22/ 07/ 2024 (date of issue) at Bhayandar

Signature with Seal: _____

Name & Address: **Dr. PRAKASH SHANKAR BORADE**

A. CHIEF FIRE OFFICER
FIRE & EMERGENCY SERVICES
MIRA-BHAINDAR MUNICIPAL CORPORATION

To,
RAHUL INTERNATIONAL SCHOOL,
 Sr. No 266 (67)/ 7, 268 (53)/ 1, 269 (54)/ 2 Village Navghar,
 Mira Road East, Dist -Thane 401107

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....

(Reasons to be recorded)

(Name and designation of the authorized signatory)