Head Office, Virar (West)
E-mail: vasaivirarcorporation@yahoo.com
Tal. Vasai Dist. Palghar - 401305

Fire Fighting and Emergency Services
Tel. No. 9822321684
E-mail: fire.vvmc@gov.in
J. No. VVISHAM/AGNI/MUKA/355/2025
Date:-09/06/2025

NOTARY R. B. YADAV Malad (E), Mumbai, (Mah) Reg. No. 15099 GOVT. OF INDIA

NO OBJECTION CERTIFICATE

To,
M/S. Rahul International School,
Near Ashwini Hospital, Patankar Park,
Nalasopara (West) Tal. Vasai Dist. Palghar

Reference:-

1) Application dated 29/04/2025 by Mr. Rahul International School.
2) Certificate of "B" form regarding the examination of fire safety system obtained from a registered licensed agency.
3) Copy of the license of the registered licensed agency.
4) Certificate of available fire extinguishing systems
5) Colour photograph of fire extinguishing systems.
6) ISI certificate of available fire extinguishing systems
7) Tax receipt
8) Map of the business premises
9) Electrical test certificate of electrical installation.
10) Guarantee letter regarding the fire extinguishing system being in use.
11) Lift (Elevator) maintenance and repair certificate
12) Air conditioning (Air conditioning system) maintenance and repair certificate
13) Actual site inspection of the Fire Department dated 15/05/2025.

As per the application submitted to the Fire Department, "Mr. Rahul International School" (3453 sq.m.) under the jurisdiction of Vasai Virar City Municipal Corporation, fire safety system to be

installed in the place of business under the name of "Mr. Rahul International School" (3453 sq.m.) and the precautions to be taken in terms of public safety, after inspecting the fire fighting system, and subject to fulfilling the following terms and conditions of this department, fire fighting technical opinion is being given only for a period of 1 year from the given date, after which it will be mandatory to renew it.

Under the "Maharashtra Fire Prevention and Life Saving Measures Act 2006", it is mandatory to keep the fire prevention and life saving measures in the building in operation at all times as specified in sub-section (1) of section 3 of the Act. As per section 3 (3), it is mandatory to keep the said system safe and efficient at all times.

1. The stairs, passages etc. in the school building are now open. It should be ensured that they remain open permanently.

2. The exits of the school are marked with signs. It should be ensured that they are visible permanently..

3. It should be ensured that the electrical system installed in the school is always in good condition.

4. If additional electrical system is to be installed in the school as per the requirement, it should be spark proof and automatically disconnected and it should be equipped with ISI Mark certified materials. Also, it should be done by a recognized electrical contractor and a certificate should be obtained that it is completely safe.

5. The school has a permanent fire extinguishing system, HC type (6 kg) 11 nos., (4 kg) 05 nos., (2 kg) 02 nos., CO2 type-4.5 kg.02 nos., 2 kg.02 nos. and buckets filled with fine sand. It is mandatory to keep them operational at all times and refill them periodically.

6. The relevant persons, employees or volunteers in the school should have at least basic knowledge about extinguishing fires,

quickly and safely evacuating patients, using fire extinguishing equipment. Training should be provided from time to time. Mock drills should be conducted once a month and records should be kept.

7. It is mandatory to pay strict attention to ensuring that the existing adequate ventilation system and alternative portable emergency light system in the building remain available permanently.

8. The telephone numbers of essential services like fire brigade, police, hospital etc. should be displayed in bold letters in the visible part of the school building. They should be seen to be permanently visible.

9. The manual electric alarm system on each floor should be kept operational at all times.

10. The concerned fire officer shall have the right to inspect the condition of the fire safety system in the building at any time.

11. It will be mandatory for all the concerned employees working in the school to conduct at least one mock drill in a year with the help of registered licensees and fire personnel.

12. No objection certificate/opinion is being given only for fire fighting matters without hindering the unauthorized construction action of Vasai Virar City Municipal Corporation.

13. It is mandatory to pay capitation fee/tax before obtaining a use license for new construction.

14. All types of government, semi-government and other permissions should be obtained from the concerned office before starting the actual business. This No Objection Certificate/Opinion should not be used as any kind of evidence. Doing so will result in legal action.

15. In case of any kind of complaint received in the school, The applicant professional will be responsible for resolving (disclosing) all kinds of complaints, The Fire Department will *not be responsible in this regard.*

16. Renewal of the No Objection Certificate will be mandatory due to changes in government decisions and fee increases from time to time.

17. The said Fire Fighting Technical Opinion will be valid for a period of 01 year only from the date of issuance. After that, while renewing the Fire Fighting Technical Opinion, it will be mandatory for you to keep the fire fighting system existing at that time operational. Also, if any accident occurs in this regard, the owner/occupier will be solely responsible.

18. You must submit the application along with the documents to this office at least one month before the expiry of the said No Objection Certificate. After the expiry of the certificate, the said certificate will be deemed to be cancelled.

19. In case of any accident resulting in financial or life loss, it should be noted that you are eligible to file a criminal case against you in that regard.

20. Certificate fee Rs. 34,600/- Receipt No. 160215, Book No. 1603, (D.D. 012553, HDFC Bank), paid on 27/05/2025.

21. It is mandatory for the owner/occupier to submit a certificate from a licensed agency every year in the months of January and July stating that the fire extinguishing system is in good working order. It should be noted that no separate demand letter will be issued to you for this.

22. The list of registered licensees is available on the website www.maharastrafireservice.org or www.mfsindia.org.

ATTESTED BY ME
11.6.25
R. B. YADAV
ADVOCATE & NOTARY
GOVT. OF INDIA
Vanshe Compound.

Hon. Chief Fire Officer
Vasai-Virar City Municipal Corporation

मुख्य कार्यालय ,विरार (पश्चिम)
ई-मेल:vasaivirarcorp oration@yahoo.com
ता.वसई जि.पालघर ४०१३०५

अग्निशमन व आपत्कालीन सेवा
भ्रमणध्वनी क्र.९८२२३२१६८४
ई-मेल : fire.vvmc@gov.in

जा.क्र. वविशम/अग्नि/मुका/३५५ /२०२५
दिनांक:-०९/०६/२०२५

ना हरकत दाखला

प्रति,
मे.राहुल इंटरनॅशनल स्कुल,
अश्विनी हॉस्पिटल जवळ,पाटणकर पार्क,
नालासोपारा (पश्चिम) ता.वसई जि.पालघर

संदर्भ:-

१) मे.राहुल इंटरनॅशनल स्कुल यांचा दि. २९/०४/२०२५ रोजीचा अर्ज.
२) अग्निसुरक्षा व्यवस्थेचे परिक्षण नोंदणीकृत अनुज्ञप्तीधारक अभिकरणाकडून प्राप्त करुन घेतले बाबतचे " ब " नमुना प्रमाणपत्र
३) नोंदणीकृत अनुज्ञप्तीधारक अभिकरणाच्या परवानाची प्रत.
४) उपलब्ध अग्निशमन यंत्रणांचे प्रमाणपत्र
५) अग्निशमन यंत्रणेचे रंगीत छायाचित्र.
६) उपलब्ध अग्निशमन यंत्रणेचे आय.एस.आय.प्रमाणपत्र
७) टॅक्स पावती
८) व्यवसाय ठिकाणाचा नकाशा
९) विज संच मांडणीचे वीज परिक्षण कलेले प्रमाणपत्र.
१०) अग्निशमन यंत्रणा वापरात असल्या बाबतचे हमी पत्र.
११) लिफ्ट (उव्दवाहक) देखभाल दुरुस्तीचे प्रमाणपत्र
१२) एअर कंडिशन्ड (वाताणुकुलीत यंत्रणा) देखभाल दुरूस्तीचे प्रमाणपत्र
१३) अग्निशमन विभागाची प्रत्यक्ष स्थळ पाहणी दि.१५/०५/२०२५.

वसई विरार शहर महानगरपालिका कार्यक्षेत्रात, अग्निशमन विभागात सादर केलेल्या अर्जानुसार "मे.राहुल इंटरनॅशनल स्कुल " (३४५३ चौ.मी.) नावाने सुरु केलेल्या व्यवसायाच्या ठिकाणी करावयाची अग्निसुरक्षा व्यवस्था व सार्वजनिक सुरक्षिततेच्या दृष्टीने घ्यावयाच्या खबरदारीचे अनुषंगाने अग्निशमन यंत्रणेची तपासणी करुन या विभागाच्या खालील शर्ती व अटींची पूर्तता करण्याचे अधिन राहून केवळ दिलेल्या तारखेपासुन फक्त १ वर्ष कालावधीसाठीच अग्निशमन तांत्रिक अभिप्राय देण्यात येत असुन तद्नंतर नुतनीकरण करणे बंधनकारक राहील.

"महाराष्ट्र आग प्रतिबंधक व जिवसंरक्षक उपाययोजना अधिनियम २००६" अन्वये अधिनियमाच्या कलम ३ च्या पोटकलम (१) मध्ये विनिर्दिष्ट केल्याप्रमाणे इमारतीमधील आग प्रतिबंधक जीवसंरक्षक उपाययोजना सदैव कार्यान्वीत ठेवणे आपणास बंधनकारक आहे. कलम ३ (३) नुसार सदर यंत्रणा सदैव सुरक्षित व कार्यक्षम ठेवणे बंधनकारक आहे.

१. शाळेच्या इमारतीत जीना, पॅसेज इत्यादी भाग जसे आता मोकळे आहेत. तसे ते कायम स्वरुपी मोकळे राहतील याची दक्षता घ्यावी.
२. शाळेच्या बाहेर पडण्याचे मार्ग चिन्हाने दर्शविण्यात आलेले आहेत तसे ते कायम स्वरुपी दिसतील याची खबरदारी घ्यावी..
३. शाळेत सद्या करण्यात आलेली विद्युत व्यवस्था सदैव सुस्थितीत राहील याची खबरदारी घेण्यात यावी.
४. शाळेत आवश्यकतेनुसार अधिक विद्युत व्यवस्था करावयाची असल्यास ती स्पार्कप्रुफ व आपोआप खंडीत होणारी असावी व ती आय.एस.आय. मार्क प्रमाणित साहित्याने परिपुर्ण असावी. तसेच मान्यताप्राप्त विद्युत ठेकेदारांकडून करून घेऊन ती पुर्णतः सुरक्षित असल्याचे प्रमाणपत्र घ्यावे.

अग्निशमन
दल

५. शाळेच्या ठिकाणी स्थायी स्वरुपाची अग्निशमन यंत्रणा, एबीसी टाईप (६ की.) ११ नग, (४ की.) ०५ नग, (२ की.) ०२ नग,सि ओ टु टाईप-४.५ कि.०२ नग,२ कि.०२ नग व बारीक वाळुने भरलेल्या बादल्या ठेवण्यात आलेले आहेत ते सदैव कार्यान्वित ठेवणे तसेच कालानुरूप रिफिलिंग करणे आपणांस बंधनकारक आहे.

६. शाळेतील संबंधित व्यक्ती, कर्मचारी अथवा स्वयंसेवक यांना आग विझविणे, रुग्णांना त्वरीत व सुरक्षितपणे आहेर काढणे, अग्निशमन उपकरणांचा वापर याबाबत किमान प्राथमिक माहिती असावी. वेळोवेळी प्रशिक्षण देण्यात यावे. महिन्यातुन एकदा मॉक ड्रिल घेण्यात यावी व त्याच्या नोंदी जतन कराव्यात.

७. इमारतीत सध्या असलेली पुरेशी वायुव्हिजन व्यवस्था (व्हेंन्टीलेशन) व पर्यायी पोर्टेबल इमरजंन्सी लाईटची व्यवस्था कायम स्वरुपी उपलब्ध राहील याकडे काटेकोरपणे लक्ष देणे बंधनकारक आहे.

८. शाळेच्या इमारतीमध्ये अत्यावश्यक सेवेचे दुरध्वनी क्रमांक जसे फायर ब्रिगेड, पोलीस, दवाखाना इत्यादींचे ठळक अक्षरात दर्शनी भागात दर्शविण्यात यावे ते कायमस्वरुपी दिसतील असे पहावे.

९. प्रत्येक मजल्यावर असलेली हस्तचलीत इलेक्ट्रिक भयसुचना यंत्रणा सदैव कार्यान्वित ठेवावी.

१०. इमारतीमधील अग्निसुरक्षा व्यवस्था यंत्रणेची स्थिती केव्हाही तपासणी करण्याचे अधिकार संबंधित अग्निशमन अधिकारी यांचेकडे राहतील.

११. शाळेतील कार्यरत सर्व संबंधित कर्मचाऱ्यांनी, नोंदनीकृत अनुज्ञप्तिधारक व अग्निशमन कर्मचारी यांचे मदतीने वर्षातुन किमान एक मॉक ड्रिल करुन घेणे बंधनकारक राहील.

१२. वसई विरार शहर महानगरपालिकेचे अनधिकृत बांधकाम कारवाईस बाधा न येता फक्त अग्निशमन बाबींसाठी ना हरकत दाखला/अभिप्राय देण्यात येत आहे.

१३. नविन बांधकामासाठी वापर परवाना घेणेपुर्वी कॅपीटेशन फी/कर भरणे बंधनकारक आहे.

१४. प्रत्यक्ष व्यवसाय सुरु करणेपुर्वी सर्व प्रकारच्या शासकीय, निमशासकीय व इतर परवानग्या संबंधित कार्यालयाकडून घेण्यात याव्यात. हा ना हरकत दाखला/अभिप्राय कुठल्याही प्रकारचा पुरावा म्हणुन वापरण्यात येऊ नये. असे केल्यास कायदेशीर कारवाई केली जाईल.

१५. शाळेत कुठल्याही प्रकारची तक्रार प्राप्त झाल्यास, सर्व प्रकारचे तक्रारींचे निरसन (खुलासा) करण्याची जबाबदारी अर्जदार व्यावसायिकांवर राहील, याबाबत अग्निशमन विभाग जबाबदार राहणार नाही.

१६. ना हरकत दाखल्याचे नुतनीकरण वेळोवेळी शासन निर्णयांत होणारे बदल व फी वाढ भरणा बंधनकारक राहील.

१७. सदरहू अग्निशमन तांत्रिक अभिप्राय निर्गमीत केल्याच्या दिनांकापासून फक्त ०१ वर्ष कालावधीसाठीच वैध राहील. तद्नंतर अग्निशमन तांत्रिक अभिप्राय नुतनीकरण करताना त्या त्या वेळी अस्तीत्वात असलेली अग्निशमन यंत्रणा कार्यान्वित ठेवणे आपणांवर बंधनकारक असेल. तसेच या संदर्भाने जर काही दुर्घटना घडल्यास त्यास सर्वस्वी मालक/भोगवटादार जबाबदार राहील.

१८. सदर नाहरकत दाखल्याची मुदत संपण्यापुर्वी किमान एक महिना आधी आपण दाखला नुतणीकरण करणेसाठी अर्ज कागदपत्रांसह इकडील कार्यालयास सादर करणे आवश्यक आहे. दाखल्याची मुदत संपल्यानंतर सदर दाखला रद्द झाला आहे असे मानन्यात येईल.

१९. जर काही दुर्घटना घडून वित्त वा जिवीत हानी झाल्यास त्या संदर्भात आपणांवर फौजदारी गुन्हा दाखल होण्यास आपण पात्र असाल याची नोंद घेण्यात यावी.

२०. दाखला फी रु.३४,६००/- पावती क्रमांक १६०२१५,पुस्तक क्रमांक.१६०३, (डि.डि.०१२५५३, एचडीएफसी बँक), दि.२७/०५/२०२५ रोजीचा भरणा.

२१. मालक/भोगवटादार यांनी दरवर्षी जानेवारी व जुलै महिन्यात लायसन्स प्राप्त अभिकरणाकडुन अग्निशमन यंत्रणा सुस्थितीत कार्यरत असले बाबत प्रमाणपत्र सादर करणे बंधनकारक आहे. यासाठी आपणांस वेगळे मागणी पत्रक देण्यात येणार नाही याची नोंद घेण्यात यावी.

२२. नोंदणीकृत अनुज्ञप्तिधारकांची यादी www.maharastrafireservice.org किंवा www.mfsindia.org या संकेत स्थळावर उपलब्ध आहे.

वसई-विरार शहर महानगरपालिका अग्निशमन दल

प्र.मुख्य अग्निशमन अधिकारी
वसई-विरार शहर महानगरपालिका

SAI SAFETY SYSTEM
CONSULTANT, CONTRACTORS
SPL. IN : FIRE ALARM & FIRE FIGHTING SYSTEMS

FORM B

[See section 3(3) and rule 4(2)]
Six monthly certificate to be given in every January and July by the owner of or the occupier for Compliance of the fire prevention and life safety Measures.

CERTIFICATE

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the Following Building or Premises namely:-
Description and Location of Building or Premises

M/s Rahul International School (CBSE),
Patankar Park, Nallasopara (West)
Tal. Vasai, Dist. Palghar

We further certify that these installations in the above mentioned building are maintained Good repair and efficient conditions during the period **1st January 2026 to 30th June 2026** in good and Healthy Condition as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act 2006 (Mah. III of 2007) the details of the Inspection of installations carried out by use is mentioned in the report appended herewith.

A. **Wet Riser Down Comer System**

1)	**Hydrant Valve**	-	**08 Nos**
2)	**Hose Reel**	-	**04 Nos**
3)	**Hose Box**	-	**01 No**
4)	**Two Way inlet**	-	**01 No**
5)	**Booster Pump 5 HP**	-	**01 No**
6)	**ABC Type Fire Extinguisher Cap 2 Kg.**	-	**02 Nos**
7)	**ABC Type Fire Extinguisher Cap 4 Kg.**	-	**05 Nos**
8)	**ABC Type Fire Extinguisher Cap 6 Kg.**	-	**11 Nos**
9)	**CO2 Type Fire Extinguisher Cap 4.5 Kg.**	-	**02 Nos**

Date- 04/08/2026
Place- Vasai, Palghar
License No:- MFS/ LA / RF- 372/ RD-386

SHRIPADSHRIVALLABH ASHOK YADAV
Digitally signed by SHRIPADSHRIVALLABH ASHOK YADAV
Date: 2026.08.04 15:40:03 +05'30'

Signature and address of the Licensed

Flat No. 203, 2nd Floor, Sharda Co-Op. Hsg. Soc. Ltd. Navghar Cross Road, No. 5 (South), Bhayandar (East)-401 105.
Mob. : 98213 88218 / 8928810788 • E-mail : sai_safety_system@yahoo.co.in